

Asbestos Action Plan - 7 Steps to Managing Asbestos (HSG 227)

OMC LLP - (Asbestos Management Compliance Strategy)

ASBESTOS REGISTER - (2008 Re-Inspection)								MATERIAL ASSESSMENT					Priority Assessment					ACM Risk Assessment Score	ACTION PLAN - (2008)										
Primary Report ID Ref No	Building	Floor	Item	Material	Bulk Analysis	Amount	Photo Ref	Asbestos Type	Product Type	Damage Deterioration	Surface Treatment	Material Score	Normal Occupant Activity	Likelihood of Disturbance	Human Exposure Potential	Maintenance Activity	Priority Score		Remove	Repair	Encap	Enclose	Decon	Label	Reinspect	No Further Action	Action by Date	Duty Holder Sign Off	
001	1	0	Board	AIB	Amosite	2 M2	1	2	2	1	1	6	2	2	2	2	8	14				X		X			06.11.08	PMcG	
002	1	1	Roof Sheet	AC	Chrysotile	3 M2	2	1	1	1	1	4	1	2	2	1	6	10			X			X			06.11.08	PMcG	
003	1	0	Pipe Work	TI	Amosite	4 Lin M2	3	2	3	3	3	11	1	2	2	0	5	16	X								06.11.08	PMcG	
004	1	1	Fire Barrier	SPR	Chrysotile	5 M2	4	1	3	3	3	10	2	2	3	3	10	20	X								06.11.08	PMcG	
005	1	G	Door Lining	AIB	Amosite	6 M2	5	2	2	1	1	6	3	1	2	1	7	13						X	X		06.11.08	PMcG	
006	1	E	Floor	DBR	Chrysotile	7 M2	6	1	3	3	3	10	2	2	2	1	7	17	X								06.11.08	PMcG	
007	1	0	Pipe Work	TI	Crocidolite	8 Lin M2	7	3	3	2	2	10	1	2	0	2	5	15			X			X				06.11.08	PMcG
008	2	0	Rain Water	AC	Chrysotile	9 Lin M2	8	1	1	1	1	4	2	0	2	1	5	9						X	X		06.11.08	PMcG	
009	2	0	Board	AIB	Amosite	2 M2	9	2	2	1	1	6	2	2	2	2	8	14				X		X			06.11.08	PMcG	
010	2	1	Roof Sheet	AC	Chrysotile	3 M2	10	1	1	1	1	4	1	2	2	1	6	10			X			X			06.11.08	PMcG	
011	2	0	Pipe Work	TI	Amosite	4 Lin M2	11	2	3	3	3	11	1	2	2	0	5	16	X								06.11.08	PMcG	
012	2	1	Fire Barrier	SPR	Chrysotile	5 M2	12	1	3	3	3	10	2	2	3	3	10	20	X								06.11.08	PMcG	
013	2	G	Door Lining	AIB	Amosite	6 M2	13	2	2	1	1	6	3	1	2	1	7	13						X	X		06.11.08	PMcG	
014	3	E	Floor	DBR	Chrysotile	7 M2	14	1	3	3	3	10	2	2	2	1	7	17	X								06.11.08	PMcG	
015	3	0	Pipe Work	TI	Crocidolite	8 Lin M2	15	3	3	2	2	10	1	2	0	2	5	15			X			X				06.11.08	PMcG
016	3	0	Rain Water	AC	Chrysotile	9 Lin M2	16	1	1	1	1	4	2	0	2	1	5	9						X	X		06.11.08	PMcG	
017	3	0	Gutter	AC	Chrysotile	10 Lin M2	17	1	1	1	1	4	2	2	2	2	8	12		X				X			06.11.08	PMcG	